

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

**Box R Waterlab**  
567 NW Second Street  
Prineville, OR 97754

Lab Order: **1506254**  
NRC Sample ID: **1506254-01A**  
Collection Date: **06/03/15 6:50:00 AM**  
Received Date: **06/04/15 3:30:00 PM**  
Reported Date: **06/11/15 12:42:22 PM**

**X018679-City of John Day**

PWS ID#: 41-00410  
Source ID: DIST-A  
Sample Comp:

Client Sample ID: Bottle # 2580  
Sample Location: 315 W Main  
Collectors Name: K.U

## ANALYTICAL RESULTS

Analyses	Code	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Copper	1022	EPA 200.8	A	0.0610		0.0005	mg/L	1.3 AL	06/08/15	CLG
Lead	1030	EPA 200.8	A	ND		0.0001	mg/L	0.015 A	06/08/15	CLG

Notes:

ND - Not Detected at the MRL  
MDL = Method Detection Limit

N.L. = No Limit

1

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Box R Waterlab  
567 NW Second Street  
Prineville, OR 97754

Lab Order: 1506254  
NRC Sample ID: 1506254-02A  
Collection Date: 06/03/15 3:50:00 AM  
Received Date: 06/04/15 3:30:00 PM  
Reported Date: 06/11/15 12:42:22 PM

X018679-City of John Day

PWS ID#: 41-00410  
Source ID: DIST-A  
Sample Comp:

Client Sample ID: Bottle # 2576  
Sample Location: 104 NE Charolais, MB  
Collectors Name: Art

## ANALYTICAL RESULTS

Analyses	Code	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Copper	1022	EPA 200.8	A	0.156		0.0005	mg/L	1.3 AL	06/08/15	CLG
Lead	1030	EPA 200.8	A	0.000114		0.0001	mg/L	0.015 A	06/08/15	CLG

Notes:

ND - Not Detected at the MRL  
MDL = Method Detection Limit

N.L. = No Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Box R Waterlab  
567 NW Second Street  
Prineville, OR 97754

Lab Order: 1506254  
NRC Sample ID: 1506254-03A  
Collection Date: 06/03/15 5:30:00 AM  
Received Date: 06/04/15 3:30:00 PM  
Reported Date: 06/11/15 12:42:22 PM

### X018679-City of John Day

PWS ID#: 41-00410  
Source ID: DIST-A  
Sample Comp:

Client Sample ID: Bottle # 2579  
Sample Location: 102 NE Charolais, Kitchen  
Collectors Name: Tony Busch

## ANALYTICAL RESULTS

Analyses	Code	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Copper	1022	EPA 200.8	A	0.106		0.0005	mg/L	1.3 AL	06/08/15	CLG
Lead	1030	EPA 200.8	A	0.000172		0.0001	mg/L	0.015 A	06/08/15	CLG

Notes:

ND - Not Detected at the MRL  
MDL = Method Detection Limit

N.L. = No Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Box R Waterlab  
567 NW Second Street  
Prineville, OR 97754

Lab Order: 1506254  
NRC Sample ID: 1506254-04A  
Collection Date: 06/03/15 5:30:00 AM  
Received Date: 06/04/15 3:30:00 PM  
Reported Date: 06/11/15 12:42:22 PM

X018679-City of John Day

PWS ID#: 41-00410  
Source ID: DIST-A  
Sample Comp:

Client Sample ID: Bottle # 2583  
Sample Location: 862 NW Bridge, Kitchen  
Collectors Name: Christal Culley

## ANALYTICAL RESULTS

Analyses	Code	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Copper	1022	EPA 200.8	A	0.0569		0.0005	mg/L	1.3 AL	06/08/15	CLG
Lead	1030	EPA 200.8	A	ND		0.0001	mg/L	0.015 A	06/08/15	CLG

Notes:

ND - Not Detected at the MRL  
MDL = Method Detection Limit

N.L. = No Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Box R Waterlab  
567 NW Second Street  
Prineville, OR 97754

Lab Order: 1506254  
NRC Sample ID: 1506254-05A  
Collection Date: 06/03/15 8:00:00 AM  
Received Date: 06/04/15 3:30:00 PM  
Reported Date: 06/11/15 12:42:22 PM

X018679-City of John Day

PWS ID#: 41-00410  
Source ID: DIST-A  
Sample Comp:

Client Sample ID: Bottle # 2584  
Sample Location: 155 NW 1st., Kitchen  
Collectors Name: C.C.

## ANALYTICAL RESULTS

Analyses	Code	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Copper	1022	EPA 200.8	A	0.123		0.0005	mg/L	1.3 AL	06/08/15	CLG
Lead	1030	EPA 200.8	A	0.000442		0.0001	mg/L	0.015 A	06/08/15	CLG

Notes:

ND - Not Detected at the MRL  
MDL = Method Detection Limit

N.L. = No Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

**Box R Waterlab**  
567 NW Second Street  
Prineville, OR 97754

Lab Order: 1506254  
NRC Sample ID: 1506254-06A  
Collection Date: 06/03/15 7:00:00 AM  
Received Date: 06/04/15 3:30:00 PM  
Reported Date: 06/11/15 12:42:22 PM

X018679-City of John Day

PWS ID#: 41-00410  
Source ID: DIST-A  
Sample Comp:

Client Sample ID: Bottle # 2581  
Sample Location: 650 W Main, Kitchen  
Collectors Name: Susie Brown

## ANALYTICAL RESULTS

Analyses	Code	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Copper	1022	EPA 200.8	A	0.266		0.0005	mg/L	1.3 AL	06/08/15	CLG
Lead	1030	EPA 200.8	A	0.00104		0.0001	mg/L	0.015 A	06/08/15	CLG

Notes:

ND - Not Detected at the MRL  
MDL = Method Detection Limit

N.L. = No Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Box R Waterlab  
567 NW Second Street  
Prineville, OR 97754

Lab Order: 1506254  
NRC Sample ID: 1506254-07A  
Collection Date: 06/03/15 8:15:00 AM  
Received Date: 06/04/15 3:30:00 PM  
Reported Date: 06/11/15 12:42:22 PM

X018679-City of John Day

PWS ID#: 41-00410  
Source ID: DIST-A  
Sample Comp:

Client Sample ID: Bottle # 2585  
Sample Location: 725 W Main, Bathroom  
Collectors Name: LCE

## ANALYTICAL RESULTS

Analyses	Code	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Copper	1022	EPA 200.8	A	0.402		0.0005	mg/L	1.3 AL	06/08/15	CLG
Lead	1030	EPA 200.8	A	0.00138		0.0001	mg/L	0.015 A	06/08/15	CLG

Notes: ND - Not Detected at the MRL  
MDL = Method Detection Limit

N.L. = No Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Box R Waterlab  
567 NW Second Street  
Prineville, OR 97754

Lab Order: 1506254  
NRC Sample ID: 1506254-08A  
Collection Date: 06/03/15 10:20:00 AM  
Received Date: 06/04/15 3:30:00 PM  
Reported Date: 06/11/15 12:42:22 PM

X018679-City of John Day

PWS ID#: 41-00410  
Source ID: DIST-A  
Sample Comp:

Client Sample ID: Bottle # 2582  
Sample Location: 230 NE Dayton, Shop  
Collectors Name: Holly Bentz

## ANALYTICAL RESULTS

Analyses	Code	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Copper	1022	EPA 200.8	A	0.179		0.0005	mg/L	1.3 AL	06/08/15	CLG
Lead	1030	EPA 200.8	A	0.000675		0.0001	mg/L	0.015 A	06/08/15	CLG

Notes:

ND - Not Detected at the MRL  
MDL = Method Detection Limit

N.L. = No Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

**Box R Waterlab**  
567 NW Second Street  
Prineville, OR 97754

Lab Order: 1506254  
NRC Sample ID: 1506254-09A  
Collection Date: 06/03/15 7:30:00 AM  
Received Date: 06/04/15 3:30:00 PM  
Reported Date: 06/11/15 12:42:22 PM

X018679-City of John Day

PWS ID#: 41-00410  
Source ID: DIST-A  
Sample Comp:

Client Sample ID: Bottle # 2577  
Sample Location: 864 NW Bridge, Kitchen  
Collectors Name: Judy Schuette

## ANALYTICAL RESULTS

Analyses	Code	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Copper	1022	EPA 200.8	A	0.214		0.0005	mg/L	1.3 AL	06/08/15	CLG
Lead	1030	EPA 200.8	A	0.000242		0.0001	mg/L	0.015 A	06/08/15	CLG

Notes:

ND - Not Detected at the MRL  
MDL = Method Detection Limit

N.L. = No Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Box R Waterlab  
567 NW Second Street  
Prineville, OR 97754

Lab Order: 1506254  
NRC Sample ID: 1506254-10A  
Collection Date: 06/03/15 6:50:00 AM  
Received Date: 06/04/15 3:30:00 PM  
Reported Date: 06/11/15 12:42:22 PM

X018679-City of John Day

PWS ID#: 41-00410  
Source ID: DIST-A  
Sample Comp:

Client Sample ID: Bottle # 2578  
Sample Location: 229 NE Dayton, Ladies BR  
Collectors Name: Angie

## ANALYTICAL RESULTS

Analyses	Code	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Copper	1022	EPA 200.8	A	0.0724		0.0005	mg/L	1.3 AL	06/08/15	CLG
Lead	1030	EPA 200.8	A	0.000570		0.0001	mg/L	0.015 A	06/08/15	CLG

Notes:

ND - Not Detected at the MRL  
MDL = Method Detection Limit

N.L. = No Limit



# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Box R Waterlab  
567 NW Second Street  
Prineville, OR 97754

Lab Order: 1509234  
NRC Sample ID: 1509234-01A  
Collection Date: 09/02/15 8:04:00 AM  
Received Date: 09/04/15 10:26:00 AM  
Reported Date: 09/17/15 12:33:56 PM

X019681 City of John Day

PWS ID#: 41-00410  
Source ID: DIST-A  
Sample Comp:

Client Sample ID: 2DBP-02  
Sample Location: S Canyon High School  
Collectors Name: CM

## ANALYTICAL RESULTS

Analyses	Code	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Dibromoacetic acid		EPA 552.2	A	ND		0.003	mg/L		09/15/15	CSB
Dichloroacetic acid		EPA 552.2	A	ND		0.003	mg/L		09/15/15	CSB
Monobromoacetic acid		EPA 552.2	A	ND		0.003	mg/L		09/15/15	CSB
Monochloroacetic acid		EPA 552.2	A	ND		0.003	mg/L		09/15/15	CSB
Trichloroacetic acid		EPA 552.2	A	ND		0.003	mg/L		09/15/15	CSB
Total Haloacetic Acids	2456	EPA 552.2	A	ND		0.003	mg/L	0.06	09/15/15	CSB
Surr: 2,3-Dibromopropionic acid		EPA 552.2		111		0	%REC		09/15/15	CSB

Notes: ND - Not Detected at the MRL  
MDL = Method Detection Limit

N.L. = No Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Box R Waterlab  
567 NW Second Street  
Prineville, OR 97754

Lab Order: 1509236  
NRC Sample ID: 1509236-01A  
Collection Date: 09/02/15 7:39:00 AM  
Received Date: 09/04/15 10:26:00 AM  
Reported Date: 09/15/15 10:01:42 AM

X019682-City of John Day

PWS ID#: 41-00410  
Source ID: DIST-A  
Sample Comp:

Client Sample ID: 2DBP-01  
Sample Location: West Reservoir #5 Tap  
Collectors Name: CM

## ANALYTICAL RESULTS

Analyses	Code	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Chloroform	2941	EPA 524.2	A	0.00208		0.0005	mg/L		09/05/15	BAY
Bromodichloromethane	2943	EPA 524.2	A	0.00145		0.0005	mg/L		09/05/15	BAY
Dibromochloromethane	2944	EPA 524.2	A	0.00132		0.0005	mg/L		09/05/15	BAY
Bromoform	2942	EPA 524.2	A	0.000730		0.0005	mg/L		09/05/15	BAY
Total Trihalomethanes	2950	EPA 524.2	A	0.00558		0.0005	mg/L	0.08	09/05/15	BAY
Surr: 4-Bromofluorobenzene		EPA 524.2		98.7		0	%REC		09/05/15	BAY
Surr: Dibromofluoromethane		EPA 524.2		107		0	%REC		09/05/15	BAY
Surr: Toluene-d8		EPA 524.2		90.9		0	%REC		09/05/15	BAY

Notes: ND - Not Detected at the MRL  
MDL = Method Detection Limit

N.L. = No Limit

1